

Office of the Regional Office

Karnataka State Pollution Control Board

Bangalore - Bommanahalli

2nd Floor, "Nisarga Bhavan",

7th 'D' Main Road, Thimmaiah Road,

Shivanagar, Bangalore-560 010.

Phone : (O) 080-23221552

ಪ್ರಾದೇಶಿಕ ಅಧಿಕಾರಿಯವರ ಕಛೇರಿ

ಕರ್ನಾಟಕ ರಾಜ್ಯ ಮಾಲಿನ್ಯ ನಿಯಂತ್ರಣ ಮಂಡಳಿ

ಬೆಂಗಳೂರು - ಬೊಮ್ಮನಹಳ್ಳಿ

2ನೇ ಮಹಡಿ, "ನಿಸರ್ಗ ಭವನ",

7ನೇ 'ಡಿ' ಮುಖ್ಯರಸ್ತೆ, ತಿಮ್ಮಯ್ಯ ರಸ್ತೆ,

ಶಿವನಗರ, ಬೆಂಗಳೂರು- 560 010.

ಫೋನ್ : 080-23221552

ಕರ್ನಾಟಕ ರಾಜ್ಯ  
ಮಾಲಿನ್ಯ ನಿಯಂತ್ರಣ ಮಂಡಳಿ



towards a cleaner Karnataka

//RPAD//

No: PCB/RO/BOM/DEO/2015-16/

11582

Date: 09 DEC 2015

To

The President/Secretary

M/s. SJR Verity Apartment Owners Welfare Association

Sy.no. 22/1, Kasavanahalli Village,

Varthur Hobli, Bengaluru East Taluk,

Bengaluru-560 035

THROUGH: HELPDESK

Sir,

Sub: Non-compliance under the provisions of Water (Prevention & Control of Pollution) Act, 1974 by your apartment at the above said address and **returning of CFO application-reg**

- Ref:
1. Board consent order no.H970 dated 06.08.2013
  2. Complaint from Sri.Govardhan Shetty, Resident of Lake Shore Homes Layout on 03.03.2014
  3. This office show-cause notice vide no.201 dated 07.04.2014
  4. Complaint from Lake Shore Homes Plot Owners Association on 16.07.2014
  5. This office show-cause notice vide no.7628 dated 10.09.2014
  6. Proceedings of Personal Hearing held on 18.10.2014 vide no.3883 dated 05.11.2014
  7. Your CFO application submitted at Helpdesk vide Regn.no.99021 dated 07.09.2015
  8. This office letter vide no.10168 dated 11.11.2015
  9. B.O memo vide no.4769 dated 25.11.2015
  10. Inspection of the apartment by the undersigned with DEO of this office on 27.11.2015
  11. Compliance report submitted by you to this office on 30.11.2015

ಶಿವನಗರ

With reference to the above subject, your attention is invited to this office letter vide ref (8) wherein you were directed to submit the manifesto copies of treated sewage disposal to BWSSB STP at Kadubeesanahalli and details on measures taken for reducing water consumption and to pay balance consent fee of Rs.250/-.

In the mean time, this office has again received complaint from Sri. R.Vinay Kumar-President, Lake Shore Homes Plot Owners Association vide B.O. memo no.4769 dated 25.11.2015, regarding the discharge of sewage by your apartment into their adjacent vacant site.

To verify the compliance to PH directions and complaint against the apartment, your apartment was inspected by the undersigned with DEO of this office vide ref (10) and the following observations were made.

1. STP of capacity 200 KLD provided for treating the domestic sewage was operating during the time of inspection.

2. During peak hours, the quantity of sewage generation was found to be more, exceeding the STP capacity.
3. The STP was not operated scientifically and capacity was found to be inadequate to handle peak flow.
4. Most of the electro-mechanical equipments were corroded due to inadequate exhaust system and poor maintenance of STP.
5. Due to the peak flow generation of sewage and inadequacy of STP, the same was discharged into inbound drains there by entering the adjacent vacant site resulting in stagnation.
6. The storm water drain within the premises was inspected and some grey water stagnation was observed in the drain indicating the discharge of untreated/ partially treated sewage into the storm water drain.
7. The untreated/ partially treated sewage was found stagnated in the adjacent vacant site
8. The overflow of sewage during peak hours is finally leading to Kaikondanahalli Lake through Lake shore homes storm water drain.
9. You are yet to provide Organic Converter for disposal of garbage from the apartment.
10. You have not fully complied with the directions of the Personal Hearing held on 18.10.2014

Further, you have submitted the compliance report on 30.11.2015 vide ref (11) which is found to be unsatisfactory upon verification. Hence, in view of the above said facts the consent application filed by you vide ref (7) cannot be processed further and same is herewith **returned along with the DD (Balance consent fee)** submitted to this office directly bearing no.119547 dated 21.11.2015 with a direction to re-submit the application after complying with the Board directions at Helpdesk, Ground Floor, Parisara Bhavan, Church Street, Bangalore-01. Also, you are once again informed to **stop discharge of untreated/treated sewage outside the premises immediately.**

Please note that, operating the STP without valid CFO from the Board is offence & attracts penal provisions under relevant sections of Water (P&CP) Act, 1974.

Yours faithfully

Sd/-

Regional Officer  
RO-Bommanahalli

Encl: Application. 100/11/2015

Copy to:

1. ZSEO-Bangalore South, Nisarga Bhavana, KSPCB, Bangalore for kind information.
2. The SEO (Infrastructure Cell), Parisara Bhavana, KSPCB, Bangalore for kind information.
3. Sri.R.Vinay Kumar-President, Lake Shore Homes Plot Owners Association, No.274, Kasavanahalli, Carmelaram (P.O) Off. Sarjapur Road, Bengaluru-560 035

P. Divesh  
Regional Officer  
RO-Bommanahalli